



DEHN Test Centre

Test report



No. 2217_FRM

- Test object: **Photovoltaic flat roof mounting system ValkPro+ L10° South (reduced size model, appr. 700 x 450 x 250 mm);** manufacturer Van der Valk Solar Systems
incl. UNI Earthing Clamps (Part-No. 540 260) with aluminium round wire (Ø 8 mm); manufacturer DEHN
- Applicant: *Van der Valk Solar Systems B.V.*
Westernesse 18
2635 BG Den Hoorn
The Netherlands
- Type of testing:
- Test of the lightning impulse current carrying capability of the test classification N (50 kA) following the principles of IEC 62561-1:2017-03 (Edition 2.0), chapter 6.3.1 and chapter 6.4.
 - Evaluation of the PV flat roof mounting system as natural down-conductor of a lightning protection system, following the principles of IEC 62305-3 Edition 2.0 2010-12, chapter 5.3.5.
- Test result:
- **The test of the lightning current capability of the photovoltaic flat roof mounting system ValkPro+ L10° South for the test classification N (50 kA) passed the criteria of IEC 62561-1.¹⁾ The test samples show no visible damages.**
 - **The assessment of the photovoltaic flat roof mounting system according to IEC 62305-3:2010-12 (Edition 2.0); chapter 5.3.5, for the compliance with the minimum dimensions is made by the applicant, see Annex A.**
- Report: 76 pages test report including 36 figures, 9 oscillograms and 3 annexes. Available upon request at Van der Valk Solar Systems.

Neumarkt, 28th March 2022

Revision: 0

Markus Fritscher
Senior Technician

Bernd Moosburger
Senior Engineer

Tobias Meyer
Head of DEHN Test Centre

1) DEHN UNI Earthing Clamps installing at the ends of the roof carrier profiles, must be positioned as shown on page 9, Figure 3!